

Name of Business	Depth Water Inside	Depth of Water Outside	# of Lost Business Days	Damage Assessment	Additional notes
Clear Lake	3.5 inches	72 inches	6 days	Already had water resistant walls installed. ServPro did have to cut holes very close to the floor to let concrete floor be cleaned not replaced; no equipment lost; sandbags provided by shipping center were used.	Water came to the bottom of the interior windows; floor drains helped drainwater away; insurance will pay for labor & construction; one of the owners car was completely submerged (insurance paid for that); she says sandbags required her to buy FEMA insurance.
Twisted Noodles	4.5 inches	2 feet	1-2 days	Damage: the only thing that was replaced was the cracked glass in the front door.	New management (annated to storms I'm told) took over Oct. 1 so employees were not sure how long they were closed; sandbags given by shipping center, were put on both front and back doors.
Rose Nails	5 inches	Unknown	11 days	Replaced floor. Replaced all chairs. Insurance?	Used sandbags. Ladies wouldn't speak to me without the owner there. Minimal loss.
Paco	6 inches	2.5-3 feet	1 day	Carpet was cleaned. Minimal damage.	Fans still going days after; animals had been moved up; tanks did not lose power; sandbags in front; flood gates were also up but missins a great, employees don't know how.
Talhamk	8 inches	1.5 feet	1 week	Partial carpet floor was cleaned; no damage to sheetrock; humidity damaged electronics.	The Hallmark store and Pink Pearl restroom have the same owner. She told me there were sandbags for the Hallmark store, but the flood doors for the Pink Pearl had been removed already to open business Sunday. She was there by herself that Monday morning and was not able to put the heavy and complicated flood doors up by herself. There were no sandbags left over for the Pearl. Flooding started in the Pink Pearl around 10:00 am on Sunday. Starbucks adjacent.
The Pink Pearl	5-6 inches	3 feet	1.5 weeks	Lost rug and dresses; stone floor upboards damaged; no sheetrock replaced.	The Hallmark store and Pink Pearl restroom have the same owner. She told me there were sandbags for the Hallmark store, but the flood doors for the Pink Pearl had been removed already to open business Sunday. She was there by herself that Monday morning and was not able to put the heavy and complicated flood doors up by herself. There were no sandbags left over for the Pearl. Flooding started in the Pink Pearl around 10:00 am on Sunday. Starbucks adjacent.
Babalu	1-2 inches inside	96 inches	1.5 weeks	Some interior damage; water came up out drains in floor.	Used flood doors helped them possess their own; no sandbags; concrete floors.
Starbucks Coffee	Unknown	4 feet	Still closed	Damaged & empty.	
Strawguy's Beagle	Unknown	4 feet	Still closed	Damaged & empty.	
MH House Properties	Basement only	Unknown	Unknown	They don't want to answer questions other than that only the basement had flooded. They directed me to ask questions to federal really.	Sandbags at front door, but basement still flooded.
McPherson's Cleaners	6 inches	Unknown	Opened outside	Truck out clothes color to Florence?	According to the demolition guy, some were concerned about the chemicals left behind to go into the ground water.
Stashout	2 inches	3-4 feet	Closed Mon and tues	~\$400 damage in plasticators, no structure or electrical damage.	Did have flood doors; they had been up an upgrade.
Waiting the City	2 inches	4 feet	10 days	3 feet of sheetrock must be replaced everywhere; new floors, ceilings.	Sandbags; both employees I spoke to thought that the flood doors had been taken down before the storm but were not sure.
Windrose	2.5-3 inches	4 feet	1 day	Minimal damage; concrete floors; had moisture testing done; clear after 48 hours.	Stainless steel flood gates.
The Beauty	1-2 inches in front, 6 in back	Above flood doors	4 days	Some water got in front door but not much - 2 inches. Most of water came in the back door - 6 inches; some product damage; walls and floor will have to be replaced; will affect their fourth quarter business because they will be in the middle of a remodel during the holidays.	They did use sandbags and also flood doors. Manager said they were the same as Trader Joe's walls but different than the ones that were used at Starbucks. They used sandbags and the steel storm doors that live behind their store; doors only took minutes to put on. Minimal water in front door; none in back. Employees, both times I visited, did not know how high the water had gotten outside; They did mention that the storm doors now need a tune up, after a flood.
Trader Joe's	Almost none	Didn't open	None	No damage.	Did have flood doors and sign bags.
Choco	None	Not directly in front	1 day	No damage.	Signage higher elevation at north end of plaza, did have sandbags though.
Spinn	None	None	1.5 days	No damage.	2 bins of sandbags & sent given to them.
Choc	No water inside	Higher elevation, didn't reach doors	1 day	No damage.	Sump pump was installed recently and helped; water came up through drains to the flood gates, which take 8 hours to install, didn't help. They had gravel coming up through drains. Management suggested to move business; Windows go to ground in some places.
Zoff's Kitchen	16 inches	Unknown	1 week	90% of kitchen equipment replaced; Health dept came and shut them down for week before to concrete.	Fish in the stormdrains, employees couldn't get out. Demolition was said the Town Inspectors Dept. had already been there.
Corner Diner	Unknown	Unknown	Unknown	Lower half of sheetrock torn out.	
Stain Mart	18-24 inches	3.5 feet	Over November	Ductwork extensive damage.	
Empty Store	Unknown	Unknown	Unknown	Sandbags; glass panels broken; Window frames pushed in by Oceanfront.	Window pushed in.
Wild Bird Centers	16-18 inches	2.5 feet	Over 3 months	Lost thousands; flood insurance covered some; rug torn out; putting in stained concrete.	Will have a grant reposition windows on all the way around.
Club Plates	3-4 inches	3 feet	A whole month	All new equipment, new floor & walls; door was cracked from water pressure; didn't know about flood insurance.	Was booted for their electronics which were put away in a box; they were given 3 sandbags.
Musical Ely	Unknown	Unknown	Opened until further notice	Duct & ceiling.	
The Loop	8 inches	4 feet	2 days	Lost 3 coolers and line cooler; did have flood insurance.	Drains in floor but they may not work bc of age; sandbags & tarp.
Bakersbox	1 foot	5 feet	1 week	Had to remove some rug.	Tarp and sandbags both; removed merchandise. Were flood ready.
Chicos	8-9 inches	Unknown	Quitted & empty	Extensive damage.	Remotion guy says they are replacing 18 inches of sheetrock.
Performance Bicycle	8 inches	4 feet	77 days	Interior damage; lots of merchandise lost.	Sandbags & tarp.
Empty Store	Unknown	Unknown	Empty	Concern for chemicals from former dry cleaner could have escaped into flood water.	
Stain Outdoor Provisions Company	11 inches	33 inches	4 days	Minimal damage due to Manager Chad Pickers who read the stream gage, steps at the store, and already had a disaster mitigation team scheduled for the next day with fans and dehumidifiers; floor will have to be replaced after holidays.	Chad@greatindoorprovisions.com; video of flood possibly on their website (unfound); leak was floating around; sandbags & high gates by shipping center.
Talbots	Unknown	Unknown	Quitted & empty	Water got inside. Completely empty.	
Borner Bird gift store & Chinese restaurant	4 inches	1.5 feet	-2 days lost, but people were still shopping during closure.	Most of the water came in the back door because the floor starts and there were no sandbags in the back; no flood insurance; carpet in office had to be torn out. Lost their internet gear, a piece of furniture, and some ribbon etc. bc of damage to walls.	Love their landlord; no flood insurance; no storm doors but sandbags; no one from town came until they had already closed; Catering Company guys helped ending outside drains immediately and banned them from their shop area.
The Shoe Repair	6 inches inside	Adjoining - 2.5 feet	1 day	Completed about dump trucks bringing soil (cement) destroyed.	Did have sandbags; were prepared; storm floors, wet vacs & fans.
Silver Work	Unknown	Unknown	Still closed	Damaged & empty.	Silver Work has retired from being a retail store and now concentrates on wholesale foods to Asian restaurants.
The Cantina Company	1 inch on North side only	8 inches - 1 foot	7 days	Most damage on North side of building towards Eastside from Maryland. Minimal because he had drains in the concrete floor; he was really concerned about his tenants; he had Shopvacs stocked up and began bringing them to them immediately, having been on the premises since 6:30am.	Sandbags 2 deep; Happened very quickly; 30-45 mins it was over.
Musicians	1 inch	1 foot	None; customers Mon.	Has flood insurance but they won't help.	
Stons	2.5 inches worse in back	2.5 feet	2.5 days	Had 18 floors replaced.	Sandbags down by landlord.
Yam Etc.	6-10 inches	Unknown	3 weeks	Had to tear out walls (8 inches of sheetrock); lost a lot of yam; squally rug torn out and replaced with new carpet flooring.	Owner = Mary Shaw maryshawest@gmail.com
Chico's	10 inches	Back/flooding	10 days	Floors replaced; walls repaired; video of back/flooding to be found.	
Caravan					
Waterproof verification product					